



| C.O. PIPE DIAMETER | PIPE MATERIAL | CAP STYLE | MID-STATES PLASTIC BOX | HYDRAULIC GRADIENT LEVEL |
|--------------------|---------------|-----------------------------------|------------------------|--------------------------|
| 4" | P.V.C. | ALL PLASTIC MECHANICAL SEWER PLUG | MSBCF-1118-18XL | BELOW GRADIENT |
| 4" | P.V.C. | P.V.C. CAP WITHOUT GASKET | MSBCF-1118-18XL | ABOVE GRADIENT |
| 6" | P.V.C. | ALL PLASTIC MECHANICAL SEWER PLUG | MSBCF-1324-12 | BELOW GRADIENT |
| 6" | P.V.C. | P.V.C. CAP WITHOUT GASKET | MSBCF-1324-12 | ABOVE GRADIENT |
| 6" | D.I. | MECHANICAL JOINT CAP | MSBCF-1324-12 | ABOVE GRADIENT |
| 8" | P.V.C. | P.V.C. CAP WITHOUT GASKET | MSBCF-1730-12 | ABOVE GRADIENT |
| 8" | D.I. | MECHANICAL JOINT CAP | MSBCF-1730-12 | ABOVE GRADIENT |

NOTES:

- CLEANOUT SHALL BE INSTALLED TO GRADE AND LOCATED 6" TO 12" ABOVE THE HYDRAULIC GRADIENT OF THE LAKE LINE WHEREVER POSSIBLE.
- CLEANOUT SHALL ALSO BE LOCATED TO PROVIDE EASY ACCESS FOR INSPECTION AND MAINTENANCE.
- FOR CLEANOUT ENCLOSURE USE MID-STATES PLASTIC METER BOX OR EQUAL. THE COVER FOR THE PLASTIC BOX SHALL BE DUCTILE IRON AND READ "SEWER", OR BE BLANK (NO LABEL).



City of Bellevue

SEWER UTILITIES

TITLE

CLEANOUT TO GRADE FOR LAKE LINE CONNECTION