



NOTES:

1. LOCATE ALL UNDERGROUND UTILITIES PRIOR TO TRENCHING OPERATIONS.
2. ROOT BARRIER PRODUCT: USE PLASTIC INTERLOCKING PANELS, 18" MIN. DEPTH X 24" TYP. WIDTH X .08" MIN. THICKNESS, WITH 90° DEFLECTION RIBBING, OR APPROVED EQUAL.
3. TREATMENT OF ROOTS EXPOSED DURING CONSTRUCTION: FOR ROOTS OVER 1" IN DIAMETER, MAKE A CLEAN, STRAIGHT CUT TO REMOVE DAMAGED PORTION OF ROOT. ALL EXPOSED ROOTS SHALL BE TEMPORARILY COVERED WITH MOIST BURLAP TO PREVENT DRYING AND COVERED WITH SOIL AS SOON AS POSSIBLE.
4. ALL PRUNING SHALL BE PERFORMED TO ANSI A300 STANDARDS.
5. ROOT PRUNING SHOULD NOT BE PERFORMED WITHIN 5 MONTHS OF LOCAL HIGH-WIND SEASON.



City of
Bellevue

TITLE:

SITE PROTECTION - TREE ROOT BARRIER

DRAWING #:	PK-IM-01C
SCALE:	N.T.S.
REVISION DATE:	12-2018
DEPARTMENT:	PARKS