



**NOTES**

1. SEE COB STD. DWG. PK-IM-07N FOR SECTION A.
2. EXISTING AND PROPOSED UTILITY LINES SHALL BE LOCATED OUTSIDE OF FACILITY UNLESS OTHERWISE APPROVED BY CITY OF BELLEVUE.
3. SIDEWALK ELEVATION AND 4" NOTCH INVERTS ELEVATION MUST BE SET ABOVE TOP OF FREEBOARD AND INLET INVERT ELEVATIONS.
4. PROVIDE A MIN. OF ONE NOTCH IN WALL AT SIDEWALK TO AVOID PONDING ALONG WALK. GRADE SIDEWALK TO DRAIN TO NOTCHES.
5. STEP OUT ZONE ADJACENT TO ON-STREET PARKING OR LOADING ZONES SHALL BE 24" MIN. WIDTH.
6. SKATEBOARD STOPS OR WALL NOTCH STOPS MAY BE REQUIRED BASED ON FACILITY LOCATION AND SIZE. WALL NOTCH STOPS SHALL BE 3" WIDE AND 3" DEEP.
7. PLANTER FENCE ANCHOR POSTS TO BE 3' O.C. MAX. WITH 2 ANCHORS AT EACH CORNER, AS SHOWN. ANCHOR BOLTS TO HAVE CAPS. SEE COB STD. DWG. PK-IM-07N FOR SECTION VIEW. FENCE MATERIAL & DETAILING PER PROJECT PLANS.



City of  
Bellevue

TITLE:

**WALLED BIORETENTION PLANTER - PLAN**

DRAWING #:	PK-IM-07M
SCALE:	N.T.S.
REVISION DATE:	08-2020
DEPARTMENT:	PARKS



Standard detail revised with support of King Conservation District