



PROVIDE 6" MIN DIA. SLOTTED STORM DRAIN PIPE PER COB STD. DWG. NDP-3 WHEN NOTED ON PLANS. SLOPE PIPE AT 0.5% MIN. UNLESS SPECIFIED OTHERWISE.

NOTES

1. SEE COB STD. DWG. PK-IM-07M FOR PLAN AND ADDITIONAL NOTES.
2. FREEBOARD TO BE 6" MAX. AND VARIES PER PROJECT.
3. SEE CITY OF BELLEVUE STORM AND SURFACE WATER ENGINEERING STANDARDS (CURRENT EDITION) FOR MATERIALS.
4. OPTIONAL WATERPROOF LINER MAY BE REQUIRED AS DIRECTED BY ENGINEER.
5. STEP OUT ZONE MAY BE REQUIRED WHEN ADJACENT TO ON-STREET PARKING.
6. SMALL TREES MAY BE ALLOWED IN WALLED BIORETENTION PLANTERS WHEN LOCATED 5' FROM UNDERDRAIN.
7. OPTIONAL WATERPROOF LINER MAY BE PROVIDED FOR NON-INFILTRATING FACILITIES. GEOMEMBRANE LINER SHALL BE PVC WITH A MIN. THICKNESS OF 30 MILS AND SHALL BE IN ACCORDANCE WITH ASTM D7176. SEAMS AND LINER SHALL BE WATERPROOF TO TOP OF FREEBOARD. WATERPROOF LINER TO EXTEND TO TOP OF FREEBOARD AND SECURED PER LINER MANUFACTURER. SUBGRADE FOR LINER PER ENGINEER. GEOTEXTILE UNDER LINER PER LINER MANUFACTURER.
8. PLANTER FENCE TO BE 12" MIN. ABOVE SIDEWALK GRADE. SEE COB STD. DWG. PK-IM-07M FOR PLAN VIEW. FENCE MATERIAL & DETAILING PER PROJECT PLANS.



TITLE: **WALLED BIORETENTION PLANTER - SECTION**

DRAWING #:	PK-IM-07N
SCALE:	N.T.S.
REVISION DATE:	08-2020
DEPARTMENT:	PARKS