



NOTES:

1. PERFORATED DRAIN PIPE TO BE N-12 PLASTIC DUAL WALL WITH SMOOTH INTERIOR AND CORRUGATED EXTERIOR. TYPICAL PIPE SPACING TO BE 15'-0" O.C. THROUGHOUT TARGET DRAIN AREA. USE 4" DIA. PLASTIC N-12 DUAL WALL SOLID PIPE FOR COLLECTION LINE(S).
2. DEPTH OF TRENCH AND DRAIN PIPE WILL VARY DEPENDING ON SITE TOPOGRAPHY. MAINTAIN NO LESS THAN 1% SLOPE FROM TARGET DRAIN AREA TO COLLECTION LINE(S) AND/OR OUTFALL. BELLEVUE PARKS MAY REQUEST FLOW TEST TO ENSURE POSITIVE DRAINAGE PRIOR TO FINAL ACCEPTANCE.
3. USE NO FILTER FABRIC UNLESS OTHERWISE SPECIFIED.
4. TOPSOIL TO BE 60% SAND, 40% COMPOST MIX FROM OWNER APPROVED VENDOR AND SHALL BE SUFFICIENTLY COMPACTED SO TO MINIMIZE SETTLING. SOIL MAY BE SLIGHTLY BERMED ABOVE FINISHED GRADE TO ACCOUNT FOR SETTLING.
5. FARM GROWN SOD SHALL BE PERENNIAL RYE GROWN LOCALLY IN THE PACIFIC NORTHWEST REGION WITHIN A MEDIUM CONTAINING NO NETTING AND LESS THAN 15% CLAY CONTENT. SOD SHALL BE CUT FROM THE SUPPLIER'S FIELD, DELIVERED TO THE PROJECT SITE AND INSTALLED WITHIN A 48 HOUR WINDOW. SOD SHALL BE INSPECTED AND APPROVED BY BELLEVUE PARKS PRIOR TO INSTALLATION.
6. GRASS SEED SHALL BE A PERENNIAL RYE MIX CONTAINING NO LESS THAN 98% PURE RYEGRASS SEED AND NO MORE THAN 0.5% WEED SEED.



City of
Bellevue

TITLE:

**DRAINAGE - SUBSURFACE DRAIN FOR GENERAL
TURF AREAS**

DRAWING #:	PK-IM-08B
SCALE:	N.T.S.
REVISION DATE:	12-2018
DEPARTMENT:	PARKS